

REQUEST FOR INFORMATION FORM

SOLICITATION NO. VA245-16-B-0049
PROJECT 688-645
EXPAND VISITOR/ PATIENT PARKING GARAGE
VAMC WASHINGTON, DC

Submitted By: (Include full name, address and phone number of company) Date: 19 July 2016

Ribeiro Construction Co., Inc.; 7385-A Old Alexander Ferry Road, Clinton, MD 20735; 301.877.1396

Point of Contact: Cindy Bladen

Reference/Subject: Intended Feed Path for Access Gate Override

Spec. Section No./Title: _____ **Page/Art./Para.** _____

Drawing No.: E2.6, Access Gate Wire Diagram **Plan/Detail/Schedule:** _____

Question: (Explain in detail)

Please note access gate switch shown on the ACCESS GATE WIRE DIAGRAM on sheet E2.6. If this gate override switch is to be provided within a security office location other than the booth directly across from this gate arm, please identify the intended path for the feed.

Response:

Gate override switch is to be located in the Security Booth room 301 shown on A1.1 column line B8.

SUBMIT ALL QUESTIONS TO THE CONTRACTING OFFICER BY E-MAIL, Robert.perry2@va.gov OR BY FAX TO (202) 745-8465.

PLEASE NOTE THE LAST DAY FOR ALL QUESTIONS IS COB JULY 19, 2016.